



B R O W N S V I L L E
PUBLIC UTILITIES BOARD

Date: August 20, 2021
To: All Vendors
Subject: Addendum #2

REFERENCE: **B075-21, SUPPLY OF POLEMOUNT AND PADMOUNT TRANSFORMERS**

Please be aware of the following information:

This Addendum forms part of the contract, and clarifies, corrects, or modifies original bid document. Line item #4 has been added to the Cost Sheet. Please use the revised page, 8-rev1, when submitting bid document.

Question 1: What is the Low Voltage of the line item #3, E1539-00?

Answer 1: The voltage for commodity number E1539-00 needs to be 4160/2400Y.

The signature of the company agent, for the acknowledgement of this addendum, shall be required.
Complete information below and return without pricing via fax (956) 983-6367.

I hereby acknowledge receipt of this addendum.

Company: _____
Agent Name: _____
Agent Signature: _____
Address: _____
City: _____ **State:** _____ **Zip:** _____
Phone #: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6375.

Hugo E. Lopez

BY: Hugo E. Lopez
Purchasing

REVISED COST SHEET

Note: THREE PHASE with **304 stainless steel enclosure (tank, lid, cabinet) Padmount Transformers**. All specifications and dimensions will remain the same.

ITEM #	QTY	DESCRIPTION	UNIT PRICE 304 STAINLESS STEEL TRANSFORMERS	EXTENDED TOTAL	DELIVERY IN DAYS (ARO)
PADMOUNT, THREE PHASE					
2	1 each	(E1525-00) 225 KVA 7200 277/480 (tap changer +/-2.5%) with Internal Fault Detector NL: LL: TL:			
3	2 each	(E1539-00) 3,000 KVA 7200, 4160//2400Y with (tap changer +/-2.5%) and Internal Fault Detector NL: LL: TL:			
4	3 each	(E1535-00) 1,500 KVA 7200 277/480 (tap changer +/-2.5%) with Internal Fault Detector NL: LL: TL:			

Note: The transformers shall be delivered FOB Brownsville Public Utilities Board, 1155 FM 511, Olmito, Texas 78575 **via open/flatbed trailer**. **Transformers shipped in an enclosed trailer will be rejected upon delivery.**

