



Date: August 26, 2021
To: All Vendors
Subject: Addendum #3

REFERENCE: B079-21, AIRPORT SUBSTATION SELF SUPPORTING STEEL STRUCTURE

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: What type of steel will be requested, a weathering steel (as stated in Specifications) or galvanized steel (as stated in the Drawing)?

Answer 1: Brownsville PUB is requesting galvanized steel for the transmission poles.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: hlopez@brownsville-pub.com or to dsolitaire@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone #: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6375.

Hugo E. Lopez

BY: Hugo E. Lopez
Purchasing