



B R O W N S V I L L E  
**PUBLIC UTILITIES BOARD**

---

Date: February 22, 2022  
To: All Vendors  
Subject: Addendum #2

**REFERENCE: B021-22 Supply of Polemount and Padmount Transformers**

This Addendum forms part of the contract, and clarifies, corrects, or modifies original bid document. Replace page 13 with the attached Revised Cost Sheet. Use the “Revised” Cost Sheet when submitting a bid response.

**Question 1:** The commodities E1508-00 and E1510-00 are listed under three phase pads instead of single phase. The more common is 12470GRDY/7200 and 240/120. Please advise.

**Answer 1:** The commodities E1508-00 and E1510-00 are single phase padmount and the voltage specifications can be found on pages 25-30. Please use the Revised Cost Sheet, page 13 rev1, when submitting bid response.

**Question 2:** Please provide voltage clarification from commodities: E1528-01, E1529-01, E1531-01, E1536-00, E1536-01, and E1537-00.

**Answer 1:** The voltages are as follows:  
E1528-01 is 12470Y/7200, 240 Delta with 120MT  
E1529-01 is 12470Y/7200, 240 Delta w/120MT  
E1531-01 is High Voltage 2400 Delta and Low Voltage 277/480Y  
E1536-00 is High Voltage 12470Y/7200 and Low Voltage 2400 Delta  
E1536-01 is High Voltage 12470Y/7200 and Low Voltage 2400 Delta  
E1537-00 is High Voltage 12470Y/7200 and Low Voltage 4160 Delta

The signature of the company agent, for the acknowledgement of this addendum, shall be required.

**Complete information below and return without pricing via email to: [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6375.

*Hugo E. Lopez*

BY: Hugo E. Lopez  
Purchasing

**REVISED  
COST SHEET**

Note: SINGLE PHASE with **304 stainless steel enclosure (tank, lid, cabinet) Padmount Transformers.** All specifications and dimensions will remain the same.

ITEM #	QTY	DESCRIPTION	UNIT PRICE 304 STAINLESS STEEL TRANSFORMERS	EXTENDED TOTAL	DELIVERY IN DAYS (ARO)
<b>PADMOUNT, SINGLE PHASE</b>					
28	150 each	(E1508-00) 100 KVA 7200 120/240 (tap changer +/-2.5%) with Internal Fault Detector NL:            LL:            TL:			
29	10 each	(E1510-00) 167 KVA 7200 120/240 (tap changer +/-2.5%) with Internal Fault Detector NL:            LL:            TL:			

**Note:** The transformers shall be delivered FOB Brownsville Public Utilities Board, 1155 FM 511, Olmito, Texas 78575 **via open/flatbed trailer. Transformers shipped in an enclosed trailer will be rejected upon delivery.**