



B R O W N S V I L L E
PUBLIC UTILITIES BOARD

Date: March 24, 2022
To: All Vendors
Subject: Addendum #1

REFERENCE: B027-22 REHABILITATION OF SOUTHMOST REGIONAL WATER AUTHORITY (SRWA) WELLS NO. 11, 12, AND 13

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Last day to submit questions is March 30, 2022.

See attached information.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. Complete and return via email to dsolitaire@brownsville-pub.com

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

If you have any further questions about the proposal, please call (956) 983-6366.

BY: *Diane Solitaire*
Purchasing



Bid NO.: 027-22

BID OPENING DATE: 04/07/2022

A D D E N D U M N O . 1

Prospective bidders are advised that for purposes of this project, all original bid requirements and Addendum No. 1 requirements as expressed herein shall be considered part of the bid package. As such, bidders are advised to recognize and comply with all aspects of this bid.

Changes:

In the “Project Manual Contract Documents and Technical Specifications for Rehabilitation of SRWA Wells No. 11, 12, and 13”, please note the following changes. The page number, section and paragraph are reprinted below to show the required changes. Deleted text is ~~stricken through~~ and added text is in **bold type**.

Page 172

Technical Specifications Section 2.7: Microbiological Testing – Second Paragraph

The CONTRACTOR shall collect and submit samples for microbiological analysis until ~~one (1)~~ **three (3)** consecutive daily water samples are free of coliform bacteria. If coliform organisms are found present in the sample, the CONTRACTOR shall resterilize the well and have the water resampled until such time as no coliform organisms are found present in ~~one~~ **three** successive daily water samples and after there is no chlorine residual in the water sample.



Seal

The Seal appearing on this document was authorized by Michael Rubinov, P.G. No. 11429 on March 23rd, 2022. TBPB Firm Registration Number: 50033

A handwritten signature in black ink that reads "Mike Rubinov".

Michael Rubinov, P.G.
R.W. Harden and Associates, Inc.

March 23, 2022
Date

Isolaire

March 23, 2022
Date

Director of Purchasing & Contracting

All Addenda issued in respect to this project shall be considered official changes to the original bidding documents. It shall be the Respondent(s) responsibility to ensure that all Addenda have been received.