

Date:April 5, 2022To:All VendorsSubject:Addendum #2

REFERENCE: B034-22 Refurbishment and Repair of Transformers

Please be aware of the following information:

This Addendum forms part of the contract, and clarifies, corrects, or modifies original bid document.

Question 1: Are we able to refurbish and repair Transformers in Mexico (Out of the Country)?

Answer 1: Yes, see reference from page 18, section 13 from proposal document. Furthermore, the awarded proposer is fully responsible and must comply with Texas Department of Transportation (TxDOT) rules and regulations, and for any other requirements related for transporting polemount and padmount transformers to and from a foreign country.

Question 2: Can we have a third company remove the oil from the transformer before shipping and dispose of it?

Answer 2: Brownsville PUB will take care contacting a third party to remove the oil, however, BPUB requires at least two weeks notice prior to shipment.

Question 3: What or whom determines size of repair?

Answer 3: Please refer to Technical Specifications, page 15, Section 6, Minor Repair, and Section 7, Recondition, to determine the size of repair.

Question 4: Can the pricing be an average of repair minor/major?

Answer 4: No, Brownsville PUB is requesting a firm price.

Question 5: How can we overcome the requirements for Items 11, 12, 13, 14 and 17 of the Bid requirements? For example, the Environmental Impairment Liability Insurance will not cover Mexico.

Answer 5: It is the responsibility of the awarded vendor to meet those requirements, and any other environmental requirements when shipping to and from a foreign country.

Question 4: Please provide a list of the number of transformers available and KVA sizes.

TRANSFORMERS		
KVA	Pad	Pole
10	0	12
15	0	14
25	6	98
37.5	43	47
50	22	22
75	15	16
100	18	5
150	1	0
167	2	5
225	1	0
500	1	0
Total	109	219

Answer 4: Below is the list of available transformers:

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return without pricing via email to: hlopez@brownsville-pub.com**.

I hereby acknowledge receipt of this addendum.

Company:		
Agent Name:		
Agent Signature:		
Address:		
City:	State:	Zip:

If you have any further questions about the Bid, call 956-983-6375.

Hugo E. Lopez

BY: Hugo E. Lopez Purchasing