



B R O W N S V I L L E
PUBLIC UTILITIES BOARD

Date: October 27, 2022
To: All Vendors
Subject: Addendum #2

REFERENCE: B005-23 Robindale Wastewater Treatment Plant Vactor Truck Disposal Facility Improvements

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: Are the pipe supports for foul airline galvanized or stainless steel?

Answer 1: Piping support system material shall be consistent with the existing duct system material type for each support system component.

Question 2: What needs to happen for the test and balance?

Answer 2: The system will only require air testing. System balancing will not be required for the new vactor truck disposal area.

Question 3: How can we set up a site visit?

Answer 3: Field visit can be coordinated through Michael Anzaldua at (956) 983-6571. Please allow for a 24-hour notice.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: dsolitaire@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____
Agent Name: _____
Agent Signature: _____
Address: _____
City: _____ **State:** _____ **Zip:** _____
Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6366.

BY: *Diane Solitaire*
Purchasing