



B R O W N S V I L L E  
**PUBLIC UTILITIES BOARD**

Date: December 8, 2022  
To: All Vendors  
Subject: Addendum #2

**REFERENCE: P 012-23 SUBSTATION POWER TRANSFORMER FIELD SERVICE TO REMOVE, DISPOSE, & REPLACE CORROSIVE OIL**

This Addendum forms part of the contract and clarifies, corrects or modifies original proposal document.

**Question 1:** May I have specific dates to beginning and ending of the project?

**Answer 1:** For the past three years, ERCOT has been issuing transmission outage restrictions that begin in mid-May and end on Mid-September. Brownsville PUB would like to begin this job by the 1<sup>st</sup> week of April 2023, the latest and to be completed before mid-May 2023.

**Question 2:** Is that for all 7 transformers or not including the Option 4?

**Answer 2:** The scope of work is for three transformers with the option to do four more depending on the total cost.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com) or e-fax (956) 574-6109.**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_  
**Agent Name:** \_\_\_\_\_  
**Agent Signature:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_  
**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Proposal, call 956-983-6375.

*Hugo E. Lopez*

BY: Hugo E. Lopez  
Purchasing