

Date: February 24, 2023 To: All Vendors Subject: Addendum #4

REFERENCE: B 024-23 SUBSTATION POWER TRANSFORMER FIELD SERVICE

This Addendum forms part of the contract and clarifies, corrects or modifies the original bid document.

NEW SUBMISSION DATE & TIME: March 8, 2023 by 5:00 PM NEW OPENING DATE & TIME: March 9, 2023 at 10:30 AM

Question 1: Can you waive the bid bond requirement for us?

Answer 1: No, each bid shall be accompanied by a bid bond or a Certified or Cashier's check payable to the order of the Brownsville Public Utilities Board, City of Brownsville, Texas for a sum not less than five (5%) percent of the total amount bid.

Question 2: Brownsville PUB is requesting electrical testing for the Filter Plant. Do you need this service for the Airport Substation and South Plant Substation?

Answer 2: No, the electrical testing service is only needed at the Filter Plant.

Question 3: The awarded vendor will need to inspect the tank. Can we add any additional unforeseen services?

Answer 3: Any additional service can be added as an option.

Question 4: Are we expected to supply a full contact kit for the LTC?

Answer 4: It would be at the Vendor's discretion to add labor and material costs for any repair kits that they might be needed. Any additional service/repair or material shall be added as optional costs.

Question 5: Please provide the name plates for the Airport Substation.

Answer 5: Brownsville PUB does not have the name plate for the Airport LTC tank.

The signa	ture of the company agent, for the acknowledgement of this addendum, shall be
required.	Complete information below and return via e-mail to: hlopez@brownsville-
pub.com	or e-fax (956) 574-6109.

I hereby acknowledge receipt of this addendum.

Company:		
Agent Name:		
Agent Signature:		
Address:		
City:	State:	Zip:
Phone Number:	E-mail address	:

If you have any further questions about the Bid, call 956-983-6375.

Hugo E. Lopez BY: Hugo E. Lopez Purchasing