



Date: May 31, 2023
To: All Vendors
Subject: Addendum #1

**REFERENCE: P035-23 15KV METAL CLAD ENCLOSED SWITCHGEAR FOR WATER
PORT SUBSTATION**

This Addendum forms part of the contract and clarifies, corrects or modifies original proposal document.

Question 1: Specifications call for an Arc Resistant option in N3R Non-walk in enclosure. Myers does not have a design for Arc Resistant gear in N3R. Would it be acceptable if we include an alternate option with the Arc Resistant gear inside a walk in enclosure?

Answer 1: Please provide both the base proposal and alternate option. If the vendor(s) is not planning on bidding for the Type 2C Arc-Resistant Switchgear Optional Item. See page 14 rev1.

DO NOT FILL IN PRICING WHEN ACKNOWLEDGING RECEIPT OF THIS ADDENDUM

The signature of the company agent, for the acknowledgement of this addendum, shall be required. Complete information below and return via e-mail to: hlopez@brownsville-pub.com or e-fax (956) 574-6109.

I hereby acknowledge receipt of this addendum.

Company: _____
Agent Name: _____
Agent Signature: _____
Address: _____
City: _____ **State:** _____ **Zip:** _____
Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Proposal, call 956-983-6375.

Hugo E. Lopez
BY: Hugo E. Lopez
Purchasing

Item	Description	Manufacturer Part Number	Quantity	Unit Cost	Extended Cost
14	Three Surge Arresters, MOV, Station Class		3	\$	\$

Spare Parts Total Cost: \$ _____

Bid Total: \$ _____

OPTIONAL

Item	Description	Cost
1	On-site Unloading assistance	\$
2	Type 2C arc-resistant switchgear	\$

Note: It only includes assistance to unload the switchgear lineup. All cables entering and exiting the equipment shall be installed by the owner. There are no relays on this switchgear. All relays will be in the substation control building.

The Owner is exempt from Texas sales tax on materials. The prices quoted shall exclude such sales and use tax.

- Price of the Equipment set forth herein shall include the cost of delivery to the Water Port Substation Site, 3160 N. Indiana Ave, Brownsville, TX 78521. Such delivery shall be made within 26 weeks ARO.

Time of Delivery shall be as follows: Monday Through Friday 9:00 a.m. to 4:00 p.m. central time.

- This Proposal is made pursuant to the provisions of the Notice and Instructions to candidate and the firm agrees to the terms and conditions thereof.
- The candidate warrants the accuracy of all statements contained in the Firm's Qualifications, if any, shall be submitted and agrees that the Owner shall rely upon such accuracy as a condition of the Contract in the event that this Proposal is accepted.
- The Firm warrants that this Proposal is made in good faith and without collusion or connection with any other person or persons bidding for the same work.
- The Firm agrees that, in the event this Proposal is accepted, it will execute a Contract in the form attached hereto.
- The Firm warrants that the Equipment will conform to the performance data and guarantees which are attached hereto and by this reference made a part hereof.
- If, in submitting this Proposal, the Firm has made any change in the form of Proposal or Contract furnished by the Owner, the Firm understands that the Owner may evaluate the effect of such change as they see fit or they may exclude the Proposal from consideration in determining the award of the Contract.