



Date: August 29, 2023  
To: All Vendors  
Subject: Addendum #2

**REFERENCE: B063-23, 138KV CURRENT TRANSFORMERS (CT) & POTENTIAL TRANSFORMERS (PT)**

This Addendum forms part of the contract and clarifies, corrects or modifies the original bid document.

**Question 1:** Are composite insulators acceptable as well?

**Answer 1:** No, composite insulators are not acceptable.

**Question 2:** Is it correct that the CTs for Palo Alto need to have an approximately 33” longer creepage distance than the CTs for Loma Alta?

**Answer 2:** Yes, that is correct.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com) or to [dsolitaire@brownsville-pub.com](mailto:dsolitaire@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6375.

*Hugo E. Lopez*  
BY: Hugo E. Lopez  
Purchasing