



B R O W N S V I L L E
PUBLIC UTILITIES BOARD

Date: August 18, 2022
To: All Vendors
Subject: Addendum #4

REFERENCE: B058-22 WPT1 Train A and Train C Concrete Structure Repair Project

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: Item #5 partial depth greater than 4”bid form has EA, should it be SF.

Answer 1: Unit of measure should be in SF.

Question 2: Can you provide details and more description concerning item 7 and item 8:
#7. Grout Pockets troughs ramps; #8. Grout wash repair – stair tread.

Answer 2: #7 - These are the grout repairs at the wall ends of the weir troughs.
#8 - These were in case the stairs treads leading to Train A needed repair. During the site visit with the contractors, it did not appear necessary. Bid as in the bid schedule in case that changes.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: dsolitaire@brownsville-pub.com**.

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6366.

BY: *Diane Solitaire*
Purchasing