

Plot Date: 5-DEC-2023 2:53:14 PM

User: svcPW

Model: Layout1 ColorTable: gshade.cab DesignScript: Carollo\_Sig\_Pen\_v0905.pen PlotScale: 1:1

LAST SAVED BY: aradcliff

1 2 3 4 5 6 7 8 9 10 11 12 13

A

B


C

D

E

F

G



**2 PHOTO**  
00S01 SCALE: NO SCALE  
FILE:



**3 PHOTO**  
00S01 SCALE: NO SCALE  
FILE:

**GENERAL NOTES:**


- FOR STRUCTURAL GENERAL NOTES SEE DWG 00GS01.
- ALL EXISTING CONDITIONS SHALL BE FIELD VERIFIED PRIOR TO BEGINNING WORK. NOTIFY THE OWNER AND ENGINEER OF ANY DIFFERING CONDITIONS IN ACCORDANCE WITH REQUIREMENT OF CONTRACT DOCUMENTS.
- ALL DETAILS ARE TYPICAL EVEN IF NOT EXPLICITLY CALLED OUT.
- FOR CONCRETE WALL AND SLAB FINISHES, SEE SPECIFICATION SECTION 03\_35\_29.
- FOR CONCRETE REPAIR DETAILS SEE SHEET 00S06/TYP. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
- NO EXPOSED REBARS, CRACKS, OR SPALLING WERE IDENTIFIED DURING THE SITE VISIT IN ALL LOCATIONS DUE TO ACCESSIBILITY. THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ENGINEER OF ANY SUCH ISSUES IDENTIFIED DURING CONSTRUCTION AND UNDERTAKE REPAIRS IN ACCORDANCE WITH THE SPECIFICATIONS AND DETAILS PROVIDED ON SHEET 00S06/TYP.

**# KEY NOTES:**

- SHALLOW SURFACE REPAIR, SEE DETAIL 1/00S06/TYP.
- DEEP SURFACE REPAIR, SEE DETAIL 2/00S06/TYP.
- ALL EXPOSED REBARS SHALL CORE DRILL 2" DIAMETER HOLE, 1 1/2" DEEP, AND CHIP AND GRIND TO REMOVE EXISTING REINFORCEMENT AND EQUIPMENT ANCHORS TO 1 1/2" MINIMUM BELOW TOP OF EXISTING CONCRETE PATCH WITH REPAIR MATERIAL.




**4 PHOTO**  
00S01 SCALE: NO SCALE  
FILE:



**5 PHOTO**  
00S01 SCALE: NO SCALE  
FILE:

REV	DATE	BY	DESCRIPTION

DESIGNED  
TIS  
DRAWN  
ERR  
CHECKED  
KMD  
DATE  
DECEMBER 2023



Digitally signed by Tuani I. Samsudeen  
Contact Info: Carollo Engineers, Inc.  
Date: 2023.12.06 14:41:26 -0500  
*Tuani Samsudeen*



BROWNSVILLE PUBLIC UTILITIES BOARD  
FLOCCULATION TRAIN STRUCTURAL IMPROVEMENTS  
STRUCTURAL  
MODIFICATION PHOTOS 1

VERIFY SCALES  
BAR IS ONE INCH ON ORIGINAL DRAWING  
0 1"  
IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY

JOB NO.  
202284  
DRAWING NO.  
00S03  
SHEET NO.  
9 OF 14