

Plot Date: 5-DEC-2023 4:16:23 PM

User: svcPW

PlotScale: 1:1

DesignScript: Carollo_Sig_Pen_v0905.pen

Model: Layout1 ColorTable: gshade.ctb

LAST SAVED BY: aracliff



6 PHOTO
00S01 SCALE: NO SCALE
FILE:



8 PHOTO
00S01 SCALE: NO SCALE
FILE:



7 PHOTO
00S01 SCALE: NO SCALE
FILE:



9 PHOTO
00S01 SCALE: NO SCALE
FILE:

GENERAL NOTES:


1. FOR STRUCTURAL GENERAL NOTES SEE DWG 00G001.
2. ALL EXISTING CONDITIONS SHALL BE FIELD VERIFIED PRIOR TO BEGINNING WORK. NOTIFY THE OWNER AND ENGINEER OF ANY DIFFERING CONDITIONS IN ACCORDANCE WITH REQUIREMENT OF CONTRACT DOCUMENTS.
3. ALL DETAILS ARE TYPICAL EVEN IF NOT EXPLICITLY CALLED OUT.
4. FOR CONCRETE WALL AND SLAB FINISHES, SEE SPECIFICATION SECTION 03_35_29.
5. FOR CONCRETE REPAIR DETAILS SEE SHEET 00S06/TYP. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
6. NO EXPOSED REBARS, CRACKS, OR SPALLING WERE IDENTIFIED DURING THE SITE VISIT IN ALL LOCATIONS DUE TO ACCESSIBILITY. THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ENGINEER OF ANY SUCH ISSUES IDENTIFIED DURING CONSTRUCTION AND UNDERTAKE REPAIRS IN ACCORDANCE WITH THE SPECIFICATIONS AND DETAILS PROVIDED ON SHEET 00S06/TYP.

KEY NOTES:

1. SHALLOW SURFACE REPAIR, SEE DETAIL 1/00S06/TYP.
2. DEEP SURFACE REPAIR, SEE DETAIL 2/00S06/TYP.
3. DEMOLISH TOP 1'-0" TO 1'-6" OF THE COLUMN WITH HAND HELD JACK HAMMER. DO NOT DAMAGE OR CUT EXISTING COLUMN REBARS. AFTER DEMOLITION IS COMPLETED, RECONSTRUCT THE TOP OF THE COLUMN WITH CLASS "A" CONCRETE, (TYP).
4. THE EXISTING SLAB SHALL BE DEMOLISHED BEFORE DEMOLISHING THE TOP OF COLUMN. REFER TO THE DEMOLITION DRAWINGS FOR ADDITIONAL REQUIREMENTS.

REV	DATE	BY	DESCRIPTION

DESIGNED	TIS
DRAWN	ERR
CHECKED	KMD
DATE	DECEMBER 2023



Digitally signed by Tuan I. Samsudeen
Contact Info: Carollo Engineers, Inc.
Date: 2023.12.06 14:41:19 -0500
Tuan I. Samsudeen



BROWNSVILLE PUBLIC UTILITIES BOARD
FLOCCULATION TRAIN STRUCTURAL IMPROVEMENTS
STRUCTURAL
MODIFICATION PHOTOS 2

VERIFY SCALES	JOB NO. 202284
BAR IS ONE INCH ON ORIGINAL DRAWING	DRAWING NO. 00S04
0 1" (Scale bar)	SHEET NO. 10 OF 14
IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY	