



B R O W N S V I L L E
PUBLIC UTILITIES BOARD

Date: February 23, 2024
To: All Vendors
Subject: Addendum #1

REFERENCE: P022-24 Purchase of Two (2) Compressed Air Systems for Water Treatment Plant 1

This Addendum forms part of the contract and clarifies, corrects or modifies original RFP document.

Question 1: Can you provide the voltage of the current compressor that is installed?

Answer 1: The voltage of the current compressor installed is 230/460, however, the available voltage for the compressors is 480v.

Question 2: Can you provide the size of the tank (Gal)?

Answer 2: The size of the tank is 120 gallons.

Question 3: If installation is needed of the new equipment, is it possible to send personnel to review the current installation?

Answer 3: Yes, installation is required for the new equipment. You may contact Daniel Tamez at (956) 983-6471 to schedule an appointment.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: dsolitaire@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____
Agent Name: _____
Agent Signature: _____
Address: _____
City: _____ **State:** _____ **Zip:** _____
Phone Number: _____ **E-mail address:** _____

If you have any further questions about the RFP, call 956-983-6366.

BY: *Diane Solitaire*
Purchasing