



B R O W N S V I L L E  
**PUBLIC UTILITIES BOARD**

---

Date: April 19, 2024  
To: All Vendors  
Subject: Addendum #4

**REFERENCE: B036-24 Phase 2 – Service Center Additional Pole Yard Fencing**

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

**Question 1:** In the written specifications section 32-31-13 on page three under 2.02 Chain-Link Fence Fabric, there are two types of vinyl coatings listed ASTM 668, class 2a and class 2b which stipulates two different methods of vinyl coating for chain-link fabric. Specify if BPUB is requesting 2a or 2b.

**Answer 1:** BPUB is requesting class 2b thermally fuse bonded coating.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [dsolitaire@brownsville-pub.com](mailto:dsolitaire@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6366.

BY: *Diane Solitaire*  
Purchasing