



Date: December 10, 2024
To: All Vendors
Subject: Addendum #4

REFERENCE: P012-25, 165 KV Metal-Clad Switchgear for the Ocelot Substation

This Addendum forms part of the contract and clarifies, corrects or modifies original proposal document.

Question 1: The “As per specifications” from addenda #2, the gear needs to be arc-resistant. Will Brownsville PUB take exception or a deviation from the specification?

Answer 1: The Metal-Clad switchgear is not required to be arc-resistant.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: hlopez@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Proposal, call 956-983-6375.

BY: Hugo E. López
Purchasing