



Date: January 31, 2025  
To: All Vendors  
Subject: Addendum #3

**REFERENCE: B024-25 Demolition of Elevated Water Storage Tank No. 5**

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

**Question 1:** Section 13 10 00 1.1.B - States to remove the pump station pump. Please provide pictures of what that is.

**Answer 1:** Disregard this note. There is no Pump Station to remove & salvage.

**Question 2:** Appendix B – tank drawings 24” inlet / outlet line - what exactly are we supposed to do with it? Cap it? Plug with concrete?

**Answer 2:** The Existing Inlet/Outlet 24” Concrete Steel Cylinder (CSC) Pipe shall be capped and/or plugged by a mechanical-restraint type fitting and not concrete.

**Question 3:** Demo spec 02220-5 - 3.6.A.5 states to remove the fence and gates all four sides?

**Answer 3:** Fence and Gates around tank property to remain in place.

**Question 4:** 3.6.A.6 states to protect all trees. Please provide clarity- all shrubs? All palm trees? If they get damaged, will they need replaced?

**Answer 4:** All existing landscape around fence shall be protected and is to remain in place. All shrubs and Palm Trees. If Palm Trees and established Shrubs get damaged, they will need to be replaced with the same or approved equal.

**Question 5:** Will the access / entry pad leading to the tank get removed?

**Answer 5:** Yes, up to fence line.

**Question 6:** Request for existing foundation details or plans.

**Answer 6:** No existing foundation construction plans nor details exist. However, EST #5 should have a similar foundation as the previously removed Southmost Elevated Storage tank which was comprised of a top slab for the booster pump and drilled piers. Contractor shall remove slab and break existing piers a minimum of 5-feet deep.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [dsolitaire@brownsville-pub.com](mailto:dsolitaire@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6366.

BY: Diane Solitaire  
Purchasing