



Date: April 22, 2025  
To: All Vendors  
Subject: Addendum #1

**REFERENCE: P045-25 WOODEN POLES RESTORATION AND STRENGTH  
UPGRADE SERVICES**

This Addendum forms part of the contract and clarifies, corrects or modifies original proposal document.

**Question 1:** I don't see where it lists the height/class of poles to be reinforced. The reason I ask is that different heights/classes of poles receive different sizes of reinforcements and is needed to provide accurate/competitive pricing. Do you have this information?

**Answer 1:** The pole sizes are 35 foot and taller, classes 3 and 4.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Proposal, call 956-983-6375.

BY: *Hugo E. López*  
Purchasing