



Date: June 30, 2025  
To: All Vendors  
Subject: Addendum #3

**REFERENCE: B063-25 BPUB Ocelot Substation Construction Bid Package**

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Please see clarifications below from the 2<sup>nd</sup> pre-bid meeting held on June 26, 2025.

**Transformer unloading:** See Substation Erection Specifications, section 10.0 Substation Main Power Transformer, in particular sections 10.2 and 10.3.

**Transformer Testing:** See Substation Erection Specifications, section 10.0 Substation Main Power Transformer, in particular section 10.5

**Transformer Oil:** See note 10 on the transformer drawing attached (DB014 - Dimensional Outline B06325.pdf). Also, see Section 3.3.2 "Oil Filling" in the attached "Virginia Transformer Installation Guide" (attached separately).

**Transformer Dry Air:** The transformer has a Nitrogen system for the nitrogen gas blanket.

**Transformer On-Site Personnel:** Virginia Transformer will provide field service supervision only. Virginia Transformer requires a 4-Week notice prior to field service start date.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [nespinoza@brownsville-pub.com](mailto:nespinoza@brownsville-pub.com) and [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_

**Agent Name:** \_\_\_\_\_

**Agent Signature:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_

**Phone Number:** \_\_\_\_\_ **E-mail address:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6353.

BY: *Diane Solitaire*  
Purchasing