



Date: July 7, 2025
To: All Vendors
Subject: Addendum #4

REFERENCE: B063-25 BPUB Ocelot Substation Construction Bid Package

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

NEW SUBMISSION DATE & TIME: JULY 11, 2025 by 2:00 PM
NEW OPENING DATE & TIME: JULY 11, 2025 at 2:15 PM

Question #1: With regards to the plumbing for the control building, do you have drawings that shows the location of the main city water and where they will need to connect to? Do you happen to have something that shows where that is so they know how many feet and man hours to allocate it to?

Answer #1: Attached separately is the Water/Wastewater utility layout.

For the wastewater, the contractor must include a boring across Morrison Road and tapping into to existing sewer line. For the water line, BPUB will perform the tap to the existing line and contractor will need to extend the line to the existing water line. Additional information in the provided specs, see sections 1.3.4, 1.5.3, 4.11, and 13.3.

Question 2: Would BPUB consider an extension for Friday, July 11, 2025?

Answer 2: BPUB approves an extension as listed above.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: nespinoza@brownsville-pub.com and hlopez@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6353.

BY: *Diane Solitaire*
Purchasing