



Date: August 7, 2025
To: All Vendors
Subject: Addendum #2

REFERENCE: B077-25 Water Treatment Residuals Removal & Disposal for Water Treatment Plant No. 1-Sludge Pond Lagoon

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: For bid comparison, how are we to calculate volume (CY) from Wet Weight (Landfill Tonnage). Will Brownsville PUB provide a formula for this?

Answer 1: The trucks hauling the sludge will get weighed before offloading and after offloading, the landfill will give the driver a weight ticket, which will provide the amount of sludge delivered in tons, we will then use the formula of tons divided by 1.48 = cubic yards.

Question 2: Is Brownsville PUB paying the Landfill tipping fees? If so, would a per dry ton unit rate be considered. This would give BPUB the advantage of contractually paying for more solid than liquids removed from the lagoons.

Answer 2: Yes, BPUB is paying the tipping fee. Only dry material will be taken to the landfill.

Question 3: When was the last time the lagoons were dredged?

Answer 3: The last time the drying lagoon in question was cleaned was in January 2022.

Question 4: Is there a survey of the current sludge conditions in the lagoon that can be shared?

Answer 4: No, a paint filter test will be conducted by BPUB staff for each load.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: dsolitaire@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6366.

BY: *Diane Solitaire*
Purchasing