



Date: September 12, 2025

To: All Vendors

Subject: Addendum #1

REFERENCE: B084-25 16-Inch Waterline Loop at Ruben M. Torres Boulevard

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: What is the engineer's estimate for this project?

Answer 1: The engineer's construction cost estimate is \$340,000.00.

Question 2: Project specifies, "or equal". Can the waterline line be directional bored under the designed path instead of open cutting the areas using equal or better materials?

Answer 2: Yes. The contractor shall provide a full-detailed plan for BPUB's approval to implement a directional bore for the installation of the waterline which must include field-verified elevations (pot-holing) of all utilities in the area. There shall not be additional costs associated with this installation method to the BPUB.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: dsolitaire@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6366.

BY: ***Diane Solitaire***

Purchasing