



Date: November 5, 2025

To: All Vendors

Subject: Addendum #1

REFERENCE: B002-26 SUPPLY OF REFURBISHED 138KV CIRCUIT BREAKERS

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: What is the control voltage set-up wiring for the Refurbished 138kv Circuit Breakers?

Answer 1: Closing, tripping and auxiliary functions shall operate on a nominal control voltage of 125 volts DC. The spring winding motor shall be a universal motor rated 120 volts AC and 125 volts DC and shall be equipped with an automatic transfer device to transfer from the preferred AC source to the DC source and back to the preferred source after a delay, when AC is available. All other motors and any heaters furnished in the breakers shall be rated for a 240 volts AC, single-phase source.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: npgalindo@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the bid, call 956-983-6368.

BY: ***Diane Solitaire***
Purchasing Department