



Date: November 13, 2025

To: All Vendors

Subject: Addendum #3

REFERENCE: B003-26 BPUB Administration Building HVAC Chiller Replacements

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: Would BPUB consider the 130 Nominal Ton Chiller for approval on this bid?

Answer 1: BPUB will consider two (2) options as follows:

Option 1: 135 nominal tons per chiller

Option 2: 130 nominal tons per chiller

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: nespinoza@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the bid, call 956-983-6353.

BY: ***Diane Solitaire***
Purchasing Department