



Date: December 29, 2025
To: All Vendors
Subject: Addendum #2

REFERENCE: B017-26 VFD REPLACEMENT FOR RAW WATER PUMPS AT WATER PLANT #1

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

The correct address for the raw water pump VFD is **Water Plant 1 - 94 West 13th Street, 78520** – The title of this solicitation will be revised to reflect the new location. To schedule a new job site visit, please coordinate with Misael Andrade: **Phone:** (956) 983-6338, **Email:** MAndrade@brownsville-pub.com

Question: Is there a full specification sheet or any detailed documentation available for the Variable Frequency Drive?

Answer: The following link provides the detailed specification pertaining the VFD we are requesting: [ATV680C25Q4X1 - Variable speed drive, Altivar Process ATV600, ATV680 Low Harmonic System, 250/200kW, 400V, IP23 | Schneider Electric UK](#)

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: ngalindo@brownsville-pub.com or hlopez@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the bid, call 956-983-6368.

BY: *Diane Solitaire*
Purchasing Department