



Date: January 22, 2026
To: All Vendors
Subject: Addendum #3

REFERENCE: B023-26 SUPPLY OF POLEMOUNT AND PADMOUNT TRANSFORMERS

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: After reviewing the attached BPUB specifications, it has been identified that the scope for three-phase pad-mounted transformers extends up to 2500 kVA. Therefore, this specification does not cover the 3750 kVA unit. Please confirm whether there is a specific specification for this transformer.

Answer 1: Please use the current BPUB transformer specification that covers units up to 2,500 kVA as the governing baseline. Bidders should align to the up-to-2,500 kVA specification where applicable and clearly note any deviations that are solely due to the higher kVA rating for BPUB review.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to hlopez@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the bid, call 956-983-6375.

BY: *Diane Solitaire*
Purchasing Department