BROWNSVILLE
PUBLIC UTILITIES BOARD

Date: April 1, 2026
To: All Vendors
Subject: Addendum #1

REFERENCE: **B035-26 Supply of Polemount and Padmount Transformers**

Please be aware of the following information:

This Addendum forms part of the contract, and clarifies, corrects, or modifies original bid document.

**Question 1:** The page numbers line up, but the item numbers do not, and I want to make sure if there is any missing line items from the Cost Sheet.

**Answer 1:** No, it is a total of six (6 ea) line items. Please use Revised Cost sheet to reflect correct line-item sequence numbers.

**DO NOT FILL PRICING WHEN ACKNOWLEDGING RECEIPT OF THIS ADDENDUM.**

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return without pricing via e-mail to hlopez@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

**Company:** _____
**Agent Name:** _____
**Agent Signature:** _____
**Address:** _____
**City:** _____ **State:** _____ **Zip:**_____
**Phone Number:**_____ **E-mail:**_____

If you have any further questions about the Bid, call 956-983-6375.

**Hugo E. Lopez**
BY: Hugo E. Lopez
Purchasing

**REVISED COST SHEET**
**B035-26**

Note: SINGLE PHASE with **304 stainless steel enclosure (tank and lid) Polemount Transformers**. All specifications and dimensions will remain the same**.**

| ITEM # | QTY | DESCRIPTION | UNIT PRICE<br><br>304 STAINLESS STEEL TRANSFORMERS | EXTENDED TOTAL | DELIVERY IN DAYS (ARO) |
|---|---|---|---|---|---|
| **POLEMOUNT, SINGLE PHASE TRANSFORMER** | | | | | |
| 1 | 6 each | (E1411-01) 15 KVA 7200 120/240 POLEMOUNT<br>(tap changer +/-2.5%) with Internal Fault Detector<br><br>NL: LL: TL: | | | |

**Note:** The transformers shall be delivered FOB Brownsville Public Utilities Board, 1155 FM 511, Olmito, Texas 78575 **via open/flatbed trailer**. **Transformers shipped in an enclosed trailer will be rejected upon delivery.**

Note: **SINGLE PHASE** with **304 stainless steel enclosure (tank, lid, cabinet) Padmount Transformers.** All specifications and dimensions will remain the same**.**

| ITEM # | QTY | DESCRIPTION | UNIT PRICE<br>304 STAINLESS STEEL TRANSFORMERS | EXTENDED TOTAL | DELIVERY IN DAYS (ARO) |
|---|---|---|---|---|---|
| **PADMOUNT, SINGLE PHASE TRANSFORMER** | | | | | |
| 2 | 5 each | (E1502-00) 37.5 KVA 7200 120/240 PADMOUNT (tap changer +/-2.5%) with Internal Fault Detector<br>NL: LL: TL: | | | |

**Note:** The transformers shall be delivered FOB Brownsville Public Utilities Board, 1155 FM 511, Olmito, Texas 78575 **via open/flatbed trailer**. **Transformers shipped in an enclosed trailer will be rejected upon delivery.**

Note: **THREE PHASE** with **304 stainless steel enclosure (tank, lid, cabinet) Padmount Transformers**. All specifications and dimensions will remain the same**.**

| ITEM # | QTY | DESCRIPTION | UNIT PRICE<br><br>304 STAINLESS STEEL TRANSFORMERS | EXTENDED TOTAL | DELIVERY IN DAYS (ARO) |
|---|---|---|---|---|---|
| **PADMOUNT, THREE PHASE TRANSFORMER** | | | | | |
| 3 | 2 each | (E1527-00) TRANSFORMER 300 KVA 7200 277/480 PADMOUNT (tap changer +/-2.5%) with internal fault detector<br><br>NL: LL: TL: | | | |
| 4 | 1 each | (E1530-00) TRANSFORMER 750 KVA 7200 120/208 PADMOUNT (tap changer +/-2.5%) with internal fault detector<br><br>NL: LL: TL: | | | |
| 5 | 6 each | (E1532-00) TRANSFORMER 750 KVA 7200 277/480 PADMOUNT (tap changer +/-2.5%) with internal fault detector<br><br>NL: LL: TL: | | | |
| 6 | 5 each | (E1538-00) 2500 KVA 7200 277/480 PADMOUNT (tap changer +/-2.5%) with Internal Fault Detector<br><br>NL: LL: TL: | | | |

**Note:** The transformers shall be delivered FOB Brownsville Public Utilities Board, 1155 FM 511, Olmito, Texas 78575 **via open/flatbed trailer**. **Transformers shipped in an enclosed trailer will be rejected upon delivery.**

## Special Instructions:

Attached are the latest approved drawings for transformer concrete pads. Please **use this as reference for the dimensions when building the unit(s)**. Underground (UD) **Concrete Pad Drawings are located on page 49**.

Price shall remain firm until an award is made and after original date of Purchase Order.
Put a "√" checkmark here: (  ), if able to keep price firm for a 90 day period.
If not, indicate length of time: _____.

**Transformers shipped in an enclosed trailer will be rejected upon delivery.**

Brownsville PUB has the right to increase or decrease quantities. In space below, stipulate whether the increase or decrease will affect bid price.

(_____) Yes, an increase or decrease in quantity affects bid price.

(_____) No, an increase or decrease in quantity will not affect bid price.

**SPECIFY MANUFACTURER: _____**

Company Name:_____

Company Address:_____

Authorized Company Representative:_____

Authorized Company Representative:_____
**Signature – Failure to sign Bid will disqualify it**

Company Address:_____

_____

Telephone #: _____

Fax #: _____

E-mail: _____