



Date: April 10, 2026  
To: All Vendors  
Subject: Addendum #3

REFERENCE: **B035-26 Supply of Polemount and Padmount Transformers**

Please be aware of the following information:

This Addendum forms part of the contract, and clarifies, corrects, or modifies original bid document.

**Question 1:** From Cost Sheet and the Technical Specifications, the clause for the single phase polemount, E1411-01, is contradicting in reference to the tap changers. Please advise and confirm what is the tap range to consider?

**Answer 1:** Brownsville PUB needs tap changers as required on the specifications for all transformers. Please include tap changer +/-2.5% on commodity E1411-01.

**Question 2:** Shall we consider amorphous for the core material to the Single-Phase Transformers? Please advise.

**Answer 2:** Brownsville PUB recommends maintaining the current transformer core requirement, which specifies grain-oriented silicon steel cores. This requirement supports standardization, compatibility with approved designs, and consistency.

**Question 3:** Shall we consider aluminum for the winding material? Please advise.

**Answer 3:** This is not explicitly listed in the BPUB technical specifications, either Al or Cu will be accepted.

**Question 4:** Kindly request to allow us to refer the standard ANSI C57.12.38, in place of ANSI C57.12.25 as it is recent version for 1-Ph Padmount Distribution Transformers. We will consider Type II arrangement in accordance with figure III.

**Answer 4:** Yes, ANSI C57.12.38 may be used in place of ANSI C57.12.25, as C57.12.38 is the superseding standard and represents the current IEEE/ANSI requirements for single-phase pad-mounted distribution transformers.

**Question 5:** Kindly provide the type of winding connection, (Vector group).

**Answer 5:** It will vary per commodity. BPUB requires either Wye-Wye or Wye-Delta.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return without pricing via e-mail to [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_  
**Agent Name:** \_\_\_\_\_  
**Agent Signature:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_  
**Phone Number:** \_\_\_\_\_ **E-mail:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6375.

**Hugo E. Lopez**  
BY: Hugo E. Lopez  
Purchasing