



Date: April 13, 2026
To: All Vendors
Subject: Addendum #1

REFERENCE: B037-26 BATTERY BANK, CHARGER, AND RACK FOR THE AIRPORT SUBSTATION

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: May you confirm if Valve Regulated Lead Acid (VRLA) cells are considered to be an acceptable battery type for this bid?

Answer 1: BPUB is requesting Vented Lead Acid (VLA) batteries and VRLA are not acceptable.

Question 2: May you provide clarification on clause 4.2, 1 - the battery charger shall be designed to recharge / float charge a battery and designed to carry continuous direct loads and intermittent loads. What is the continuous load?

Answer 2: The continuous load is 6 amps.

Question 3: Could you provide historical pricing references available for this item or similar items?

Answer 3: Historical pricing is not available at this time.

Question 4: May you provide previous bid results.

Answer 4: For prior bid results, please contact BPUB Open Records Department at openrecords@brownsville-pub.com

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: nespinoza@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ State: _____ Zip: _____

Phone Number: _____ E-mail address: _____

If you have any further questions about the Bid, call 956-983-6353.

BY: *Diane Solitaire*
Purchasing Department