



Date: April 16, 2026
To: All Vendors
Subject: Addendum #2

REFERENCE: B037-26 BATTERY BANK, CHARGER, AND RACK FOR THE AIRPORT SUBSTATION

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

Question 1: The Brownsville Public Utilities Board (BPUB) battery specifications call for lead-calcium and checking if a lead-selenium battery is acceptable.

Answer 1: BPUB is looking to follow the specifications to request lead calcium batteries only. Lead-selenium batteries are not acceptable.

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: nespinoza@brownsville-pub.com.**

I hereby acknowledge receipt of this addendum.

Company: _____

Agent Name: _____

Agent Signature: _____

Address: _____

City: _____ **State:** _____ **Zip:** _____

Phone Number: _____ **E-mail address:** _____

If you have any further questions about the Bid, call 956-983-6353.

BY: *Diane Solitaire*
Purchasing Department