



Date: May 12, 2026  
To: All Vendors  
Subject: Addendum #2

**REFERENCE: B039-26, Annual Supply of Electrical Inventory Material**

This Addendum forms part of the contract and clarifies, corrects or modifies original bid document.

**Question 1:** Do the switchgears, E0969-01 and E0972-01, need to be submersible?

**Answer 1:** The switchgears are 3 phase outdoor padmount ground level and designed for the distribution of electrical power.

**Question 2:** Will you accept Line Hardware if it is a direct equal?

**Answer 2:** Yes, any equal product will be reviewed/evaluated, and must meet technical specifications. See page 3 as reference in special instructions, section "Or Equal".

The signature of the company agent, for the acknowledgement of this addendum, shall be required. **Complete information below and return via e-mail to: [hlopez@brownsville-pub.com](mailto:hlopez@brownsville-pub.com).**

I hereby acknowledge receipt of this addendum.

**Company:** \_\_\_\_\_  
**Agent Name:** \_\_\_\_\_  
**Agent Signature:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**City:** \_\_\_\_\_ **State:** \_\_\_\_\_ **Zip:** \_\_\_\_\_  
**Phone Number:** \_\_\_\_\_ **E-mail:** \_\_\_\_\_

If you have any further questions about the Bid, call 956-983-6375.

**Hugo E. Lopez**  
BY: Hugo E. Lopez  
Purchasing